

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 01:05 pm

PWS ID: UTAH27017 **Name:** SPRINGDALE TOWN WATER SYSTEM
Legal Contact: SPRINGDALE **Rating:** Approved
ROBERT STOY, III TOTTEN **Rating Date:** 03/11/1980
Address: PO BOX 187 **Activity Status:** Active
SPRINGDALE, UT 84767
Phone Number: 435-772-3434
City Served (Area):
County: WASHINGTON COUNTY
System Type: Community **Last Inv Update:** 12/27/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 12/31/2008 **Total Dsgn Cap:**
Population: 377 **Surveyor:** WILLIAM B BIRKES **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	TOTTEN, ROBERT STOY, III		435-772-3434	435-772-0402	rtotten@infowest.com

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0.75	270
Commercial	Metered	0	125
			395 Total Svc Connections

Storage

Total Storage: 3,950,000 GAL **Number of Units:** 5 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST002	500K STORAGE TANK	Ground	500,000 GAL	Concrete		A	NO
ST003	200K ANASAZI TANK	Ground	200,000 GAL	Steel		A	NO
ST004	1 MILLION GALLON TANK	Ground	1,000,000 GAL	Concrete		A	NO
ST000	RAW WATER TANK	Ground	2,000,000 GAL	Concrete		A	NO
ST001	250K RAW WATER TANK	Ground	250,000 GAL	Concrete		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	ZION PARK INTERTIE CHLORINATOR		A	
TP005	VIRGIN RIVER WTP		A	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	RAW WATER PUMP STATION	A		P			
PF002	WTP 400 GPM CLEARWELL	A		P			
PF003	BOOSTER PUMP STATION	A		P			
PF004	ANASAZI PUMP STATION	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	UTAH27051 ZION PARK INTI	Active	CC				No	GW	Emergency		
WS002	HUMMINGBIRD WELL	Active	WL	6	120 GPM	120 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	WELL #2 CEM	Inactive	WL	8	40 GPM	40 GPM	Yes	GW	Other		
WS004	BIG SPRING INTAKE	Active	IN				Yes	SW	Permanent		
WS005	VIRGIN RIVER INTAKE	Active	IN				Yes	SW	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*